


REVISIONS FOR DWG # F11410

REV	CH.NO.	DESCRIPTION	DATE	REVISED BY
-	-	ORIGINAL DESIGN	06/08/16	ARON G



AWG	mm ²	Barrel Length	Industry Standard		DIN Standard		L	L ₂	D	S	D ₂	S ₂
14	2.0800	8	F111408Y		-		15	8	2.0500	0.1500	4.2000	0.3000
14	2.5000	6	FID1406				13	6	2.2000	0.1500	4.2000	0.2500
14	2.5000	8	2206.0	FID1408	2845.0		15	8	2.2000	0.1500	4.2000	0.2500
14	2.5000	10	FID1410				17	10	2.2000	0.1500	4.2000	0.2500
14	2.5000	12	2401.0	FID1412	2846.0		19	12	2.2000	0.1500	4.2000	0.2500
14	2.5000	18	2207.0	FID1418	2847.0		25	18	2.2000	0.1500	4.2000	0.2500
12	4	8	FID1208				16	8	2.8000	0.2000	4.8000	0.3000
12	4	10	2208.0	FID1210	2848.0		18	10	2.8000	0.2000	4.8000	0.3000
12	4	12	2402.0	FID1212	2849.0		20	12	2.8000	0.2000	4.8000	0.3000
12	4	18	2209.0	FID1218	2850.0		26	18	2.8000	0.2000	4.8000	0.3000
10	6	12	2210.0	FID1012	2851.0		20	12	3.5000	0.2000	6.3000	0.3000
10	6	18	2211.0	FID1018	2852.0		26	18	3.5000	0.2	6.3000	0.3000

UNLESS OTHERWISE SPECIFIED
 • ALL DIMENSIONS ARE IN MILLIMETERS
 • THIRD ANGLE PROJECTION

• TOLERANCE	
XX	± 1.00 mm
XX.X	± 0.50 mm
XX.XX	± 0.20 mm
ALL	± XX mm

CIRTEK

This Drawing is the property of

Altrech Corp.[®]

35 Royal Road
 Flemington NJ 08822-6000
 (908) 806-9400 • Fax (908) 806-9490

AND IS A CONFIDENTIAL DISCLOSURE
 LENT WITHOUT CONSIDERATION OTHER
 THAN THE BORROWER'S AGREEMENT
 THAT IT SHALL NOT BE REPRODUCED,
 COPIED, LENT, OR DISPOSED OF
 DIRECTLY OR INDIRECTLY NOR USED
 FOR ANY PURPOSE OTHER THAN THAT
 FOR WHICH IT IS SPECIFICALLY
 FURNISHED.

TITLE: UL Single Insulated Wire Ferrules
 14AWG to 10AWG

DRAWN BY: Aron Gyorgypal	06/08/16	DRAWING NO.: M-Cad-6FU-F11410	REV.: -
CHECKED BY: Morgan E	06/08/16		
RELEASED BY: Laszlo G	06/09/16	SCALE: -	SHEET: 1 OF: 1