

Product Discontinuation

PDN-PS-6999-2021

Business Unit	Product Line Code	Type of Change	Action	Date of Issue
PS - Power Supplies	CMU	Product Discontinuation	Notify Distributors and Field	7/1/2021

Phoenix Contact's factory has announced the following product(s) is going to be discontinued. Existing specifications will be met or exceeded. Technical support of the discontinued product will continue, as required. Please review and acknowledge this document and take the appropriate action with respect to your existing inventory and ordering replacement parts.

Description for Product Discontinuation

Purpose of change:

Discontinuation of the Phoenix Contact UPS-BAT... with 7.2Ah battery. This is due to the announcement by Panasonic to cease production of this battery. The change of capacity for 7.2Ah to 7.0Ah does not effectively change the estimated hold up times that are shown in the product literature. There is no change in form or fit between the two products. The new item is a direct replacement.

Detailed Description of the change:

Successor item 1274118 UPS-BAT/PB/24DC/7Ah includes, battery type BP7-12FR
New replacement battery kit for above battery: 1283119 UPS-BAT-KIT/PB/2X12/7AH includes, battery type BP7-12FR

Identifying Characteristics:

New Order Number (1274118) and Designation (UPS-BAT/PB/24DC/7Ah)
Begin shipping: 8/2021
New Order Number (1283119) and Designation (UPS-BAT-KIT/PB/2X12/7Ah)
Begin shipping: 9/2021

Availability of existing items:

Phoenix Contact USA maintains the ability to produce and deliver the original 7.2Ah (2320319) battery for most of the existing orders. Orders that cannot be filled with 2320319, the new item (1274118) will be substituted.

Replacement battery kit 2908234 will continue to ship until inventory is exhausted.

Additional Notes:

The change in battery manufacturer and slight change in capacity does not necessitate any programming changes for any attached UPS modules. The standard battery replacement process resets the UPS to see the new battery module.

The new 7.0Ah replacement battery kit cannot be used as a replacement for any 7.2Ah batteries currently installed in applications. Once a 7.2Ah battery requires replacement, a one-time full battery replacement is required to the new 7.0Ah assembly.

Stock Status

Can existing stock still be used?

Is mixture of stock acceptable?

Transaction Dates

Last Buy from Phoenix Contact:

8/30/2021

Last Scheduled Ship from Phoenix Contact:



Phoenix Contact Inc.
P.O. BOX 4100
Harrisburg, PA 17111-0100
Phone: 717-944-1300

Product Discontinuation

Should you have any issues with the timeline or content of this product discontinuation, please contact Phoenix Contact using the information below. Customers should acknowledge receipt of the PDN within 30 days of delivery of the PDN; provided, however, that the failure to acknowledge receipt does not affect the product discontinuation or the effective date thereof.

Contact Info:

Ken Allwine
kallwine@phoenixcontact.com

Thank you,

Mike Garrick

Prod Mkt Mgr Power Sol



Phoenix Contact Inc.
P.O. BOX 4100
Harrisburg, PA 17111-0100
Phone: 717-944-1300

Product Discontinuation

Discontinued Part #	Type Description	Replacement Part #	Type Description
2320319	UPS-BAT/VRLA/24DC/7.2AH	1274118	UPS-BAT/PB/24DC/7AH
2908234	UPS-BAT-KIT-VRLA 2X12V/7,2AH		